



Job Name: _____		
Job No: _____	JWC Representative: _____	
Tag No.: _____	Submitted By: _____	Date: _____
Engineer: _____	Approved By: _____	Date: _____
Contractor: _____	Order No.: _____	Date: _____

JVPG Series

Non-Code Galvanized Storage Tanks
 Certified to NSF/ANSI Standard 61
 For Potable Water Systems
 Suitable for Temperatures
 up to 73°F



MODEL NUMBER	MAWP	TANK VOLUME		A DIAMETER		B HEIGHT		C DIM	D DIM	E DIM	EST WEIGHT	
		GAL	L	IN	MM	IN	MM				LBS	KG
JVPG-12-301	75	12	45	12	305	26½	673	3	5	13	27	12
JVPG-12-303	75	21	80	16	406	26⅝	683	3	12	14	45	20
JVPG-12-304	75	30	114	16	406	38¾	984	3	8	20	52	24
JVPG-12-305	75	42T	159	16	406	51	1295	3	12	26	71	32
JVPG-12-306	75	42S	159	20	508	34	864	3	8	17	74	34
JVPG-12-307	75	82	310	20	508	63	1600	3⅝	12	33	114	52

Dimensions are subject to change.
 Weights are approximate.